

## **SECTION 26: MONUMENTS**

---

**26-01 MONUMENTS.** Standard City monuments shall be constructed at the locations shown on the plans or as directed by the Engineer and specified herein. Monuments shall be constructed to the dimensions and details shown on the Standard Details, and shall be installed after placing the asphalt concrete surface.

Concrete shall be Class A or B conforming to the requirements of Section 90, "Portland Cement Concrete," of the Standard Specifications. Aggregate used shall conform to the grading requirements of three-quarters of an inch (3/4") maximum combined aggregate sizes.

Castings shall be tough gray iron; free from cracks, holes and swells; shall be of workmanlike finish; and shall conform to ASTM A48, Class 30B.

The solid brass monument marker, as shown in the Standard Details, shall be set in the concrete before the concrete begins to set. The Engineer shall stamp the marker for the Contractor.

**26-02 MEASUREMENT.** Monuments shall be measured on a per-each basis.

**26-03 PAYMENT.** The contract unit price for each monument, in place, shall include full compensation for furnishing all materials, labor, equipment and performing all work necessary to complete the monuments, but not including locating and stamping the marker as required in the Special Provisions, shown on the Plans and specified herein.